

ACCREDITATION DOCUMENT

F-06/02

Issue Date: 10/08/15

Rev. No: 07 LAB 087

Accreditation No: LAB 087

Awarded to

Pak Elektron Limited Transformer Testing Lab,34 Km Ferozepur Road Lahore, Pakistan.

The scope of accreditation is in accordance with the standard specifications outlined in the following page(s) of this document. The accredited scope shall be visible and legible in areas such as customer service, sample-receiving section etc and shall not mislead its users.

The accreditation was first time granted on **14-05-2015** by Pakistan National Accreditation Council.

The laboratory complies with the requirements of ISO/IEC 17025:2005.

The accreditation requires regular surveillance, and is valid until 13-05-2018.

The decision of accreditation made by Pakistan National Accreditation Council implies that the organization has been found to fulfill the requirements for accreditation within the scope.

The organization however, itself is responsible for the results of performed measurements/tests.

PAKISTAN NATIONAL ACCREDITATION COUNCIL

| Date | Director General |
|------|------------------|



ACCREDITATION DOCUMENT

F-06/02

Issue Date: 10/08/15

Rev. No: 07 LAB 087

Testing Laboratory.

Accreditation Scope of Pak Elektron Limited Transformer Testing Lab,34 Km Ferozepur Road Lahore, Pakistan.

| Permanent | lahoratory | nremises |
|------------------|--------------|----------|
| 1 Ci mancii | iabul atul y | premises |



| Materials/Pr oducts tested | Testing field (e.g. environmental testing or mechanical testing) | Types of test/ Properties measured | Reference to standardized method (e.g. ISO 14577- 1:2003)/ Internal method reference |
|--|--|--|---|
| Distribution Transformers (10 kVA to 10000 kVA up to 33kV) Electrical Testing | | Measurement of Voltage Ratio and Check of Phase displacement | IEC 60076-1 IEC 60076-3 |
| | | Measurement of Winding Resistance (HV & LV) | |
| | | Measurement of No Load Losses & Current | |
| | Measurement of Short Circuit Impedance and Load Losses | DDS-84-2007 Amended to date | |
| | Electrical Testing | Induce Over Voltage Withstand Test | |
| | | High Voltage (Separate Source Voltage Withstand Test) | |
| | Measurement of Di- Electric Strength of Transformer Oil | IEC 60422 DDS-84-2007 Amended to date | |

| Date | Director |
|------|----------|